



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Boblo Island Water Treatment Plant

Quarterly Report

Operated by the Ontario Clean Water Agency (OCWA)
under contract to the Boblo Island Development
For the period ending: March 31, 2003

Introduction

This report is a summary of the last quarter's water quality, published in accordance with Ontario's Drinking Water Protection Regulation. It includes important information regarding the source of your water, analytical test results, and how it compares to standards set by the Province. If you have any questions regarding this report, please contact our Client Services Representative listed in section 3 below.

During this quarter, the Ontario Clean Water Agency (OCWA) conducted more than 36 bacteriological tests for water quality parameters. We are proud to report that last quarter, your water met all Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. In addition, the quantity of water supplied during this quarter did not exceed the rated maximum capacity. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water system.

Compliance With Provincial Regulations

OCWA operates your water facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs:** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.

- **Operation by Licensed Operators:** Your water treatment plant is operated and maintained by the OCWA's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical Requirements:** OCWA follows a sampling and analysis schedule required by OWRA Regulation 459/00, the Ontario drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures:** To ensure the protection of the public health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of Environment and the Ministry of Health.

System Information

Facility Name:	Boblo Island Water Treatment Plant
Total Design Capacity:	2000 m ³ /day
Raw Water Source:	Detroit River
Disinfection Method:	Chlorine (gaseous)
Municipal Location:	Amherstburg
Service Area:	Central/Western Area
Service Population:	500
Client Services:	Anthony Pizans
Phone Number:	519-344-7420
E-mail Address:	apizans@ocwa.com
Operations Manager:	Chuck Fiddy
Phone Number:	519-736-5447
E-mail Address:	cfiddy@ocwa.com

Operational Description

Coagulation/Flocculation:	Aluminum sulphate, Poly electrolytes
Filtration:	Anthracite, Dual Media
Disinfection Method:	Chlorine (gaseous)
Waste effluent/residual Disposal:	Direct to water course

Summary & Discussion of Quantity of Water Supplied

The maximum flow rate for the Boblo Island WTF is 335 m³/day between November fifteen and March fifteen according to Cof A (No.0630-5GYS3L). The monthly average flow for this quarter was 34 m³/day, and the maximum daily flow was 149 m³/day. The quantity of water supplied during this quarter did not exceed the rated maximum capacity.

Analytical Test Results

Microbiological Parameters	January	February	March	Quarter Summary	MAC / IMAC
Total Coliform					
Counts/100ml	0	0	0	0	0
Number of Samples	12	12	12	36	
Number of Detectable Results	0	0	0	0	
Max. Exceedences					
Fecal Coliform					
Counts/100ml	0	0	0	0	0
Number of Samples	12	12	12	36	
Number of Detectable Results	0	0	0	0	
Max. Exceedences					
Heterotrophic Plate Count					
Number of Samples	12	12	12	36	
Max	1	3	1	3	500 Max
Exceedences	0	0	0	0	
Chlorine Residual					
Min. Chlorine residual	0.50	0.52	0.66	0.50	0.05
Exceedences	0	0	0	0	
Turbidity					
Number of Samples	62	56	62	180	
Max.	0.14	0.17	0.17	0.17	1.0
Exceedences	0	0	0	0	

Availability of Analytical Test Results

The certificate of approval from the Ministry of the Environment, and Regulation 459/00 set out monitoring requirements for your water. The tables above summarize all the results required for inclusion in quarterly reports. Your water is extensively tested for the presence of dozens of compounds. Some compounds, not listed above, may be present in low concentrations and their presence does not necessarily mean that the water poses a health risk. Results of all analytical tests are available through your municipal office.

Definitions and Abbreviations

- **MAC** - Maximum Acceptable Concentration.
- **IMAC** - Interim Maximum Acceptable Concentration.
- **Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.
- **Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm-blooded animals and humans.
- **Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.
- **Organic Parameter** - a group of chemical compounds containing carbon.
- **Inorganic Parameter** - a group of chemical compounds not containing carbon.
- **Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.