

## SUMMARY REPORTS FOR MUNICIPALITIES

### Report

This report is a summary of water quality information for the Amherstburg WTF, published in accordance with Schedule 22 of Ontario’s Drinking-Water Systems Regulation for the reporting period of January 1, 2004 to December 31, 2004. The Amherstburg WTF is categorized as a Large Municipal Residential Drinking Water System.

This report was prepared by The Ontario Clean Water Agency on behalf of The Corporation of the Town of Amherstburg.

### Who gets a copy of the Report?

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;
- in the case of a drinking-water system owned by a municipal service board established under section 195 of the *Municipal Act, 2001*, the members of the municipal service board; or
- in the case of a drinking-water system owned by a corporation, the board of directors of the corporation.

### What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system’s approval and any order that the system **failed to meet** at any time during the period covered by the report and specify the duration of the failure; and
- (b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Safe Drinking Water Act	None to report			
Ontario Regulations (eg. O.Reg 170/03, O.Reg 435/93, O.Reg 903	None to report			
System Certificate of Approval #8120-53VMF5	None to report			
Provincial Officer’s Order #1780-5XMM73	None to report			

### What else must the Report contain?

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows and daily instantaneous peak flow rates.

Attached please find a copy of the Process Data Report for Amherstburg WTF which contains all required flow information.

2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval.

By comparison, the rated capacity and flow rates did not exceed the requirement.

Flow	Maximum Daily Flow	Requirement	Maximum Flow Rate	Requirement
	Annual Maximum in 2004 (per day)	Maximum amount taken per day	Annual Maximum (per minute)	Maximum amount taken per minute
Raw Flow	16,090,000 l/d	22,900,000 l/d Permit to Take Water (#02-P-1254)	11,174 l/min	15,903 l/min Permit to Take Water (#02-P-1254)
Treated Flow	14,390 m <sup>3</sup> /d	18,184 m <sup>3</sup> /d Cof A (#8120-53VMF5)	-	-

**When Does the Report Get Submitted?**

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

End